



CLASS 'C' BACKFILL SHALL BE USED IN AREAS WITHIN RIGHT-OF-WAY WHERE ASPHALT PAVEMENT, CONCRETE CURB, SIDEWALK, DRIVEWAY, AND GRAVEL SURFACING IS NOT ANTICIPATED.

NOTES:

1. CONTRACTOR SHALL COMPLY WITH THE MOST CURRENT OSHA REQUIREMENT FOR EXCAVATIONS.
2. CLASS 'C' BACKFILL SHALL COMPLY WITH REQUIREMENTS OF THE CITY'S STANDARDS CONSTRUCTION SPECIFICATIONS.
3. TRENCH MATERIAL SHALL BE PLACED IN MAX. OF 6" LIFTS.
4. IN EXISTING RIGHT-OF-WAY TRENCH EXCAVATION SHALL NOT BE MORE THAN 100 FEET AHEAD OF THE PIPE LAYING OPERATION.
5. TRENCHES ARE TO BE BACKFILLED AT THE END OF EACH DAY.
6. ANY ALTERATIONS TO THIS STANDARD MUST HAVE WRITTEN APPROVAL BY CITY ENGINEER.
7. WITHIN RETENTION SWALE, COMPACTION EFFORT OUTLINED BY ENGINEER OF RECORD AND APPROVED BY CITY ENGINEER, TO ALLOW FOR INFILTRATION.

CITY OF LEWISTON, IDAHO
PUBLIC WORKS DEPARTMENT

**BACKFILL
CLASS 'C'**

APPROVED FOR PUBLICATION <i>Shawn J. Stubbs</i> 3/5/13 City Engineer	DWG. NO. 1-5
Date	