



**NOTES:**

1. DETECTABLE WARNING PATTERN TILE SHALL BE YELLOW TRUNCATED-DOME TYPE.
2. RAMP SLOPES SHALL NOT BE STEEPER THAN 12H:1V.
3. A 4' x 4' MIN. CLEAR SPACE WITHIN THE CROSSWALK AREA AND 4' x 4' LANDING AREA AT TOP OF RAMP W/ 2% SLOPE IN ALL DIRECTIONS.
4. PLACEMENT OF DRAINAGE STRUCTURES, JUNCTION BOXES OR OTHER OBSTRUCTIONS WITHIN/ OR FRONT OF RAMP OR LANDING IS PROHIBITED.
5. THIS RAMP SHALL BE USED WITH HIGH BACK AND ROLLED CURB.

\\Standards\2010-Standards\2-Concrete\Perp\_Type1.dwg

CITY OF LEWISTON, IDAHO PUBLIC WORKS DEPARTMENT	
<b>DOUBLE SIDEWALK RAMPS - TYPE 1</b>	
APPROVED FOR PUBLICATION <i>Shawn Shultz</i> 9/11/10 City Engineer	DWG. NO. <b>2-11</b>
Date	