



**NOTES:**

1. FIRE HYDRANT SHALL BE WATEROUS PACER WITH 16" UPPER STANDPIPE, UNLESS OTHERWISE APPROVED BY CITY ENGINEERS.
2. HARRINGTON STORZ ADAPTER (4 1/2" NH x 5" STORZ) AND BLIND CAP (5" STORZ) W/ AIRCRAFT CABLE AT THE 4 1/2" PUMPER NOZZLE.
3. FIRE HYDRANT SHALL BE SPACED AT A MAX. OF 500 FEET IN RESIDENTIAL AREAS AND 300 FEET IN COMMERCIAL AREAS.
4. A MINIMUM 3 FOOT RADIUS OF UNOBSTRUCTED STABLE LEVEL WORKING AREA SHALL BE PROVIDED AROUND ALL HYDRANTS AND NOT WITHIN HIGH WATER AREA.
5. GRIP PACKS OR ALL THREAD REQUIRED WITH THRUST BLOCK.

CITY OF LEWISTON, IDAHO PUBLIC WORKS DEPARTMENT	
<b>FIRE HYDRANT W/ SHUT-OFF VALVE</b>	
APPROVED FOR PUBLICATION <i>Shawn Stuber</i> 2/24/20 City Engineer	DWG. NO. <b>4-12</b>
Date	