



- NOTES:
1. 1043 GALLONS/VERTICAL FOOT CAPACITY.
  2. WIDE FLANGE INSTALLATION BY CONTRACTOR
  3. 4" - 6" KOR N SEAL BOOTS @ INLET/OUTLET PENETRATIONS.

REBAR:

WALLS: #6 @ 6" O.C. HORIZONTAL  
 #4 @ 10" O.C. VERTICAL

TOP & BOTTOM: #6 @ 6" O.C. SHORT DIRECTION  
 #4 @ 10" O.C. LONG DIRECTION

WEIGHTS/SECTION:

TOP: 19097#  
 WALL: 4575# PER VERTICAL FOOT  
 BOTTOM: 19097#

H-20 TRAFFIC BEARING  
 NO SUBSURFACE WATER PRESENT  
 (WILBERT PRECAST PRODUCT # 916 3000 GI  
 - HEAVY LOAD OPTION OR APPROVED EQUIVALENT)

<b>CITY OF LEWISTON, IDAHO PUBLIC WORKS DEPARTMENT</b>	
<b>3000 GALLON GREASE INTERCEPTOR</b>	
APPROVED FOR PUBLICATION <i>Shawn Stephens</i> 6/2/10 City Engineer	DWG. NO. <b>I-9</b>
Date	